

LANTERN DETAILS

LANTERN	LENS	MNTG.	BALLAST/ FINISH	VOLTS	OPTIONS
			WATTAGE		
PG2	POLY	DBLE	MHL100	CLEAR 277	N/A

POLE DETAILS

TYPE	FINISH	O.D.	HEIGHT	MATERIAL	WALL
ATTACHED TO BASE	FLUTED 12 FLUT	5"	12'	EXTRUDED	.188

BASE DETAILS

TYPE	O.D.	HEIGHT	MATERIAL
CB32 "OHIO I"	18"	18"	CAST ALUM

FLUTED POLE 12 FLUTES, 5" O.D. 12' HIGH .188 WALL THICKNESS, EXTRUDED ALUMINUM.

ANCHOR BOLTS 3/4" X 18" X 4" BURIED IN CEMENT SLAB. ALLOW 2 1/2" - 3" OF CLEARANCE FROM GROUND ZERO

POLE IS CIRCUMFERENTIALLY WELDED TO CAST BASE

CAST BASE - CB32 CAST ALUMINUM BASE .75 WALL THICKNESS

SPECIFICATIONS

PART NUMBER =
CB32-44-5F12-44-PA67-44-PG2-2-AF23-2-44-MHL100-2

CAST BASE - CB32 "OHIO I"
- HEIGHT = 18"
- WIDTH = 18"
- .75 WALL THICKNESS
- 1" THICKNESS MOUNTING PLATE
- MATERIAL = CAST ALUMINUM
POLE - FLUTED - 5F12
- OD = 5"
- HEIGHT = 12"
- MATERIAL = EXTRUDED ALUMINUM
- WALL THICKNESS = .188
- FINISH = FLUTED, 12 FLUTES
POST ARM - PA37
- HEIGHT = 15"
- LENGTH = 35"
- MATERIAL = CAST ALUMINUM
LANTERN - PG2
- HEIGHT = 22"
- O.D. = 14"
- LENS TYPE = CLEAR POLYCARBONATE
- MAX WATTAGE = 250 (HID)
= 1000 (INC)
= 42 (CF)


BALLAST - MHL100
- WATTAGE = 100w
- TYPE = METAL HALIDE, MULTITAP
- 277VOLTS (OTHER IF SPECIFIED)

****NOTE**** COMPLETE FIXTURE TO BE PAINTED WHITE - COLOR CODE # 44

****NOTE**** LAMP PROVIDED BY OTHERS. U.L. LISTED.

****WARNING****
THIS FIXTURE MUST BE GROUNDED IN ACCORDANCE WITH LOCAL CODES OF THE NATIONAL ELECTRICAL CODE; FAILURE TO DO SO MAY RESULT IN SERIOUS PERSONAL INJURY.

CB32 - BOLT PATTERN 14-1/2" BOLT CIRCLE



****NOTE****
FABRICATION TO BEGIN AFTER DRAWING HAS BEEN APPROVED, SIGNED AND FAXED BACK TO AMERICAN NAIL PLATE LTG, INC.

NOTE; PLEASE REFER TO DRAWING NUMBER LISTED ABOVE FOR ORDERS OR INQUIRIES.

NOTE; PLEASE SIGN OFF ON THIS DRAWING AND FAX BACK TO ANP LIGHTING SHOULD THIS BE ACCEPTED. _____